



WIMPEY LABORATORIES L.L.C.

TEST CERTIFICATE

(This certificate is not valid without a hologram)


Sample : High Pressure Decorative Compact Panel
(Sample ID : CLADS9506-SUEDE)


Ref. No. : Nil
Issued To : SAMRAT PLYWOOD LIMITED
SCO No. 827, 1st Floor, NAC Manimajra,
Chandigarh - 160101, INDIA

Report No. : 1010814
Report Date : 04/11/2024
Job Code STRC/BM/1010814
Sample Received On : 01/11/2024
Sample Quantity : 3pcs

S. No.	Test	Result	Test Method
1.	Thermal Conductivity, W/m. ² K	0.24	EN 12664-2001
2.	Thickness, mm	5.897	By micrometer

Signed for and on behalf of Wimpey Laboratories L.L.C.


S. Sarath Kumar
Head of Department



Test results relate only to the samples tested.
This report shall not be reproduced except in full without the written approval of the laboratory.
- End of text -